

JUL 11 2000

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens Street
Kokomo, IN 56901-3188

07/06/2000

Job Number: 00.03337
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSIS

Sample Number	Sample Description	Date Taken	Date Received
269751	WEEKLY SAMPLE	06/29/2000	06/30/2000

TestAmerica, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.


Project Representative

JUL 11 2000

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens Street
Kokomo, IN 56901-3188

07/06/2000

Job No.: 00.03337
Page 2 of 3

Date Received: 06/30/2000
Job Description: WASTEWATER ANALYSIS

Sample Number / Sample I.D.	Result	Flag	Sample Date/ Units	Analyst & Date Analyzed	Method	Reporting Limit
269751	WEEKLY SAMPLE		06/29/2000			
Zinc, ICP	0.041		mg/L	crm / 07/05/2000	EPA 200.7	<0.020

KEY TO ABBREVIATIONS

- < Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- % Percent; To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- * Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/L Part per million; Concentration in units of milligrams of analyte per Liter of aqueous sample.
- ug/L Part per billion; Concentration in units of micrograms of analyte per Liter of aqueous sample.
- mg/kg Part per million; Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion; Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- l Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.
- uj Indicates the result is below the Reporting Limit and is considered estimated.
- z Indicates the BOD dilution water blank depletion was between 0.2 and 0.5 mg/L.

MIL0005647

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: [1]

Discharge Limitations

Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02			Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
Pb	Lead[5]	0.10			Semi-Annual	Composite[2]
Ni	Nickel[5]	0.80			Semi-Annual	Composite[2]
Ag	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc[5]	1.25	0.041	6-29-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
OIL + GREASE HYDROCARBONS	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)			1 X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
*	TTO	2.13			Semi-Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)			1 X Month	Composite[2]

SEND TTO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR CATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0005648

DATE: JUNE 29,2000

MILBANK MANUFACTURING COMPANY

TIME	METER READING	INITIALS
7:30	436380	SLH
8:00	436570	SLH
8:30	436700	SLH
9:00	436900	SLH
9:30	437090	SLH
10:00	437290	SLH
10:30	437420	SLH
11:00	437580	SLH
11:30	437760	SLH
12:00	437910	SLH
12:30	438150	SLH
1:00	438340	SLH
1:30	438530	SLH
2:00	438700	SLH
2:30	438910	SLH
3:00	439100	SLH
3:30	439120	SLH

Please Test for the following items:
(Zinc [5])

June 29th, 2000

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge Limitations

Monitoring Requirements

<u>Regulated Parameter</u>	<u>Maximum for Any one Day mg/L</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Cadmium[5]	.02	Semi-Annual	Composite[2]
Total Chromium[5]	2.0	Semi-Annual	Composite[2]
Copper[5]	0.60	Semi-Annual	Composite[2]
Cyanide	0.50	Semi-Annual	Grab
Lead[5]	0.10	Semi-Annual	Composite[2]
Nickel[5]	0.80	Semi-Annual	Composite[2]
Silver[5]	0.24	Semi-Annual	Composite[2]
Zinc[5]	1.25	1 X Week	Composite[2]
Oil and Grease[6]	100	Semi-Annual	Grab
TPH[6]	(Monitor and report)	Semi-Annual	Grab
pH	6-10	Daily	Grab
CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
COD [4]	(Monitor and report)	1 X Month	Composite[2]
TSS [4]	(Monitor and report)	1 X Month	Composite[2]
Flow	N/A	Daily [3]	
TTO	2.13	Semi-Annual	Grab
Phenol	0.50	Semi-Annual	Grab
Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]